

**FIRE SAFETY CERTIFICATE**

No. : 34596/KKN/RFO/2026

Dated: 10-09-2026

Certified that the Vidyanjali School at 17-18-1/1, Near R.T.O. Office, NFCL Road, Sowjanya Nagar, Kakinada, comprised of One basement(s) and Three (upper floors) owned/occupied by VIDYANJALI SCHOOL have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 07-09-2026 (date of inspection) in the presence of P. Phaneshwari, Principal, Vidyanjali School, Kakinada and that the building / premises is fit for occupancy up to classes X With effect from 10-09-2026 for a period of One year in accordance with rule and subject to compliance of specific conditions as appended:-

- 1) This NOC is issued only in the Fire Safety Point of View and this does not give the Applicant a . right to claim ownership of the property,.
- 2) All fire safety systems provided shall be maintained in trim working condition at all times.
- 3) Electrical Safety:
  - I. Use of FRLS cables.
  - II. Proper grounding and lightning protection.
  - III. Install Co2/Clean Agent/Aerosol automatic flooding system in all electrical panels.
  - IV. No overloading or to have a different power socket for different equipment.
  - V. Electrical wiring to be changed for every 10 years wherever high power consuming appliances such as Air conditioners etc

Issued on 10-09-2026(date of issue) at Rajahmundry (place) by

\*Strike out whichever is not applicable.

Signature with Seal:  .....

Name : E. Swamy

Designation : R.F.O

To

Name&AddressofDepartment/Office: Rajahmundry

Vidyanjali School, Kakinada  
(Name & Address of the Institution)

**ENDORSEMENT**


The No Objection Certificate is issued by Fire Service stand cancelled and annulled due to .....

(reasons to be recorded).

(Name and designation of the authorized signatory)

\*The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

  
Correspondence  
VIDYANJALI SCHOOL  
KAKINADA

  
PRINCIPAL  
VIDYANJALI SCHOOL  
KAKINADA

**Government of Andhra Pradesh****A.P. State Disaster Response and Fire Services Department****No Objection Certificate for Occupancy.**

To  
THE DISTRICT EDUCATIONAL  
OFFICER, KAINADA DIST,  
KAKINADA,  
KAKINADA DIST, KAKINADA  
Sir/Madam,

File No: 34596/KKN/RFO/2026

Date: 10/09/2026

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - No Objection Certificate for Occupancy to the existing / newly constructed Non Multi Storeyed Building (**VIDYANJALI SCHOOL SPONCERED KRISHNA INSTITUTE OF MEDICAL TECHNOLOGY**) SMT V SANDYA, DNO: 70-18-1/1, NFCL ROAD, NEAR RTO OFFICE, KAKINADA, KAKINADA DIST - Regarding.

Ref: 1. Online Application Dt. 05-09-2026, SMT V SANDYA, DNO: 70-18-1/1, NFCL ROAD, NEAR RTO OFFICE, KAKINADA, KAKINADA DIST  
2. Online Inspection Report submitted by Officers of this Department on 07-09-2026.

-- x --

It is to inform that SMT V SANDYA applied for No Objection Certificate on 05-09-2026 for Occupancy to the existing / newly constructed Non Multi Storeyed Building for (**VIDYANJALI SCHOOL SPONCERED KRISHNA INSTITUTE OF MEDICAL TECHNOLOGY**) at DNO: 70-18-1/1, NFCL ROAD, NEAR RTO OFFICE, KAKINADA, KAKINADA DIST. The officers of the department have scrutinized the information, documents and plans submitted by the applicant along with the undertaking provided by the applicant, and have submitted the following report.

**VIDYANJALI SCHOOL SPONCERED KRISHNA INSTITUTE OF MEDICAL TECHNOLOGY DNO: 70-18-1/1, NFCL ROAD, NEAR RTO OFFICE, KAKINADA, KAKINADA DIST**

2. The builder has constructed a Non Multi Storeyed Building with Ground Floor + 3 Upper Floors with a height of 13 Mtrs for Educational Occupancy (Category - B1) in a total plot area of 620.00 sq. meters.  
3. Open Spaces:

**NOTE: It is the responsibility of the local Municipal authorities i.e., Municipal Corporations, Panchayats, IALA, SEZ, APIIC etc., to ensure the setbacks as per local building rules are in force vide G.O.Ms.No.44 Home (Prisons & Fire) Department Dated:12-03-2024.**

4. The builder has constructed following means of escape:

| Sl    | Details of Staircases | Required Nos / Meters as per NBC | Provided Nos / Meters |
|-------|-----------------------|----------------------------------|-----------------------|
| 1     | Internal Staircases   | Min 1 No. - 1.5 Meters           | 1 No. - 1.50 Meters   |
| Total |                       | 1.5 Meters                       | 1.50 Meters           |

5. The builder has proposed to provide Occupant Load :

| Sl | Floor  | Built up area (Sq Mtrs) | Occupancy Type | No of Occupants as declared by the builder | No of Occupants as per NBC | Aggregate width of Staircases Required (Meters) | Aggregate width of Staircases Provided(Meters) |
|----|--------|-------------------------|----------------|--------------------------------------------|----------------------------|-------------------------------------------------|------------------------------------------------|
| 1  | ground | 413                     | Educational    | 103                                        | 103                        | 1.03                                            | 1.50                                           |
| 2  | first  | 413                     | Educational    | 103                                        | 103                        | 1.03                                            | 1.50                                           |
| 3  | second | 413                     | Educational    | 103                                        | 103                        | 1.03                                            | 1.50                                           |
| 4  | third  | 413                     | Educational    | 103                                        | 103                        | 1.03                                            | 1.50                                           |
|    | Total  | 1652                    |                | 412                                        | 412                        |                                                 |                                                |

6. The minimum Fire Fighting Installations required and provided as per Table 7 of Part 4 of National Building Code of India 2016 are:

| Sl | Fire Safety System                           | Minimum Required | Provided                  |
|----|----------------------------------------------|------------------|---------------------------|
| 1  | Fire Extinguishers                           | 20 Nos.          | 20 Nos.                   |
| 2  | Hose Reel Systems                            | 4 Nos.           | 4 Nos.                    |
| 3  | Down Comer                                   |                  | 1 Nos<br>(For Each Floor) |
| 4  | Manually Operated Electric Fire Alarm System |                  | 4 Nos.                    |
| 5  | Terrace Tank                                 | 10000 Ltrs       | 10000Ltrs<br>Ltrs         |
| 6  | Booster Pump                                 | 450 LPM          | 450 LPM                   |

7. Challan Info:

| Challan Number | Challan Date | Challan Amount |
|----------------|--------------|----------------|
| 11193258422026 | 2026-09-05   | 18200          |

8. The Officers of the department have recommended to issue The No Objection Certificate for Occupancy of Non MSB Educational Building (B1) belonging to **SMT V SANDYA DNO: 70-18-1/1, NFCL ROAD, NEAR RTO OFFICE, KAKINADA, KAKINADA DIST**, subject to the following conditions.

**The No Objection Certificate for Occupancy is issued subject to the following conditions:**

1. This NOC is issued only in the Fire Safety Point of View and this doesnot give the Applicant a right to claim ownership of the property.
2. All fire safety systems provided shall be maintained in trim working condition at all times.
3. **Electrical Safety:**
  - i. Use of FRLS cables.
  - ii. Proper grounding and lightning protection.
  - iii. Install CO2/Clean Agent/Aerosol automatic flooding system in all electrical panels.
  - iv. No overloading or to have a different power socket for different equipment.
  - v. Electrical wiring to be changed for every 10 years wherever high power consuming appliances such as Air conditioners etc.

- vi. LED lights in closed rooms, corridors, staircases connected to inverter (battery) to ensure well-lighted pathways for exit or evacuation in spite of regular power failure in any emergency.
- vii. Grounding/Earthing shall be done.
- viii. Transformers shall be protected with 4 hours rating fire resistant construction with smoke vent to outside, unless separated from main building by 6 meters distance.
- ix. One foam trolley of 22.5 litres capacity at electrical transformer as mandatorily required as per IS 2190.

Periodically electrical safety inspection shall be conducted by an electrical engineer once a year.

- 4. All Security/ Maintenance personnel shall be trained on the usage of fire equipment provided.
- 5. Fire Drills shall be conducted once in every 3 months.
- 6. As per report of Non MSB Inspection committee; the NOC Committee has scrutinized the Inspection Committee Report along with Proposals and recommended for issuance of No Objection Certificate for Occupancy subject to the following Conditions.

| Sl | As Builder                                                                                                                                         | As Occupant                                                                                                    | As Security Personnel                                                                                                                                            |
|----|----------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1  | All the fire protection arrangements shall be maintained in good condition as seen during inspection.                                              | All the escape/exit routes shall not be kept locked/blocked or encroached                                      | All the occupants must know the correct method of operation of the fire fighting system installed.                                                               |
| 2  | Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management. | All occupants shall be trained to operate the fire safety equipments during emergency.                         | Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.                                                      |
| 3  | Addition / alteration, if any in the building may be verified by building authority.                                                               | Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.    | All security personnel shall be trained to operate the fire safety equipments during emergency.                                                                  |
| 4  | This No objection Certificate for occupancy is valid for one year from the date of issue of this letter                                            | Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once from nearest safe exit. | Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows. |

- 7. This No Objection Certificate for Occupancy is valid for a period of one year only from the date of issue of this letter. It is the responsibility of the builder to apply for Renewal of No Objection Certificate for Occupancy, duly remitting the User Charges as per G.O.Ms.No.218, Home (Prison & Fire) Department, dated.22-12-2023, before expiry of this No Objection Certificate.

- 9. The following deficiencies/suggestions are identified by the officers of the department and need to be attended to by the management.

Recommended : The DDRFO & FSIO -Kakinada : The management applied for Occupancy NOC from fire services department ,without obtaining provisional NOC from fire services department. By remitting Rs:18200.00 Vide challan no:11193258422026 Dated :05/09/2026 The management provided fire fighting equipment as per table 7,part IV,NBC-2016.The inspection committee DFO,Kakinada and FSIO,Kakinada were tested fire fighting equipment and found in working condition . Therefore the inspection committee is recommended for Occupancy No Objection Certificate Sir

Note: This Fire No Objection Certificate shall remain valid only subject to continuous compliance with all the conditions stipulated herein and maintenance of all Fire Prevention, Fire Protection and Life Safety Measures, systems and equipment in proper and fully operational condition at all times. If, during any inspection or random verification, any such measure, system or equipment is found non-functional, defective or not maintained as prescribed, or if the Management fails to comply with any condition within the period stipulated in the affidavit/undertaking furnished by it, this Fire No Objection Certificate shall be liable to cancellation by the Issuing Authority, notwithstanding the validity period specified herein, without prejudice to any other action permissible under the applicable Act and Rules.

10.The applicant/management must train 40% of their total work force on 3 days Basic Firefighting Course under AP Fire Services and Civil Defence Training Institute, Sattenapalli or Regional Training Centres of the Department.

In view of the above, as per the recommendations of the NOC Committee, the No Objection Certificate for Occupancy is hereby issued to the existing Non Multi Storeyed Building subject to the above conditions.

**"Safe School, Safe Hospital & Fire Safety Society-Together for Fire Prevention"**

**"सुरक्षित विद्यालय, सुरक्षित अस्पताल एवं अग्नि सुरक्षा के प्रति जागरूक समाज आग की रोकथाम के लिए एक साथ"**

**"సुरక్షిత పాఠశాలలు, సురక్షిత ఘృత ఆసుపత్రులు మరియు అగ్నిమాపక భద్రతపై స్పృహ ఉన్న సమాజం మంటలను నివారించడానికి కలిసి పనిచేస్తాయి."**



Your Sincerely,

*[Signature]*  
10/9/26  
Regional Fire Officer  
Zone-2,Rajahmundry,  
Andhra Pradesh.

***In case of emergency, please call 101 or 0884-2374571 or 9963726854***

Copy to SMT V SANDYA, THE MANAGEMENT OF m/s VIDYANJALI SCHOOL SPONCERED KRISHNA INSTITUTE OF MEDICAL TECHNOLOGY DNO: 70-18-1/1, NFCL ROAD, NEAR RTO OFFICE, KAKINADA, KAKINADA DIST

Copy to Chief Office for Record Purpose

Copy to District Fire Officer concerned

Copy to Assistant District Fire Officer concerned

Copy to Station Fire Officer concerned